

FIRE DEPARTMENT REGULATIONS

E Z EXPO SERVICES

440 E. BONITA AVE. POMONA CA 91767

909-624-1697 FAX: 909-626-6589

email: julio@sprenzents.com

For Exhibits, Exhibitions, Display, and Trade shows – Public or Private

BOOTH CONSTRUCTION

- Booths, platforms, and space dividers shall be of materials that are flame-retardant or rendered so, satisfactory to Fire Department representatives.
- Covering for counters or tables used within or as part of the booth shall be flame-retardant.
- All electrical wiring and apparatus will be of a wire UL type approved.

FIRE DEPARTMENT

A permit shall be required for the following:

- Display and operate any heater, barbecue, heat-producing or open flame device, candles, lamps, lanterns, torches, etc.
- Display or operate any electrical, mechanical, or chemical device, which may be deemed hazardous by the Fire Department.
- Use or storage of flammable liquids and dangerous chemicals.
- Display any internal combustion engine (special requirements available on request).

OBSTRUCTIONS

Aisles and exits, as designated on approved show plans, shall be kept clean, clear, and free of obstacles. Booth construction shall be substantial and fixed in position in specified area for the duration of the show. Easels, signs, etc. shall not be placed beyond the booth area into aisles. Fire fighting equipment shall be provided and maintained in accessible, easily seen locations, and may be required to be posted with designating signs.

FIRE-RETARDANT TREATMENT

All decorations, drapes, signs, banners, acoustical materials, cotton, paper, hay, straw, moss, split bamboo, plastic cloth, and similar materials shall be flame-retardant to the satisfaction of the Fire Department. Booth identification banners and signs shall be flame-retardant unless smaller than 1,232 square inches (28" x 44") if separated from other combustibles by a minimum of 12' horizontally and 24" vertically. Oil cloth, tar paper, nylon, and certain other plastic materials cannot be made flame-retardant and their use is prohibited.

COMBUSTIBLES

Literature on display shall be limited to reasonable quantities (one-day supply). Reserve supplies shall be kept in closed containers and stored in a neat and compact manner in a location approved by the Fire Department. All exhibit and display empty cartons must be stored in an approved drayage area. If show is under a 24-hour approved manned Security program, motor vehicles are allowed to retain ¼ tank or less in fuel and gas caps must be taped. Batteries are to be disconnected and taped.

PROPANE CONTAINERS

Containers having a maximum capacity of 12 pounds (nominal 5 pounds LP Gas capacity) are permitted to be used temporarily inside of buildings for public exhibition or demonstration purposes.